



Danny Brevard <danny@accent-us.com>

Tennessee acceptance of Dri-sump Containment Tightness Testing

Don Taylor <Don.Taylor@tn.gov>

Mon, Feb 11, 2019 at 1:34 PM

To: Danny Brevard <danny@accent-us.com>

Cc: "info@Dri-sump.com" <info@dri-sump.com>

Good afternoon Danny,

Tennessee accepts any release detection method which has been third party evaluated and listed by the NWGLDE. The technician utilizing the method is required to follow all manufacturer's instructions and complete the report form provided by the manufacturer. I have some questions related to cold weather and some of our staff have requested a field demonstration. Can I call you later this week to discuss?

Thanks,



Don N. Taylor | Environmental Fellow

Division of Underground Storage Tanks

Johnson City Environmental Field Office

2305 Silverdale Drive

Johnson City, TN 37601

423-854-5391 phone

Don.Taylor@tn.gov

www.tn.gov/environment/

From: Danny Brevard [mailto:danny@accent-us.com]

Sent: Monday, February 11, 2019 1:33 PM

To: Don Taylor

Cc: info@Dri-sump.com

Subject: Tennessee acceptance of Dri-sump Containment Tightness Testing

***** This is an EXTERNAL email. Please exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. - STS-Security*****

[Quoted text hidden]