



Danny Brevard <danny@accent-us.com>

---

## Form Submission - New Form - Dri-Sump

---

**Unkles, Ted** <Ted.Unkles@vermont.gov>

Wed, Jun 19, 2019 at 9:55 AM

To: Danny Brevard <danny@accent-us.com>

Cc: ANR - WM UST <ANR.WMUST@vermont.gov>

Hi Danny – I will send out a formal letter soon, but I wanted to let you know that the Vermont UST will allow the use of the Dri-Sump method with some restrictions. Because the method has not been tested if water is higher than the bottom of the sump being tested, we will accept the use of Dri-Sump only if the testing technician has verified that the water table is four feet or more below finished grade. Additionally, because Dri-Sump has not been tested when soil is frozen, we will only accept Dri-Sump results when the test was conducted between April 10 and November 15.

So, as long as the water table is at least 4 feet below finished grade, and the test is conducted during the time of year when the ground is not frozen, we will accept Dri-Sump test results.

As I mentioned before, I will send a formal letter soon, but I wanted to let you know of our conditional approval now.

[Quoted text hidden]