



Danny Brevard <danny@accent-us.com>

Alaska Acceptance of NWGLDE listing for Dri-sump™ Containment Tightness Test Method

Brinkerhoff, Larry D (DEC) <larry.brinkerhoff@alaska.gov>

Tue, May 14, 2019 at 4:10 PM

To: Danny Brevard <danny@dri-sump.com>

Cc: "Paige, Cheryl E (DEC)" <cheryl.paige@alaska.gov>, "Young, Susan R (DEC)" <susan.young@alaska.gov>

Danny,

Thank you for sending the PowerPoint slideshow for the Dri-sump containment testing equipment and protocol. I received it yesterday and was able to review it today along with the previous .pdf you sent back in the middle of last month.

I am pleased to inform you that Alaska will accept the Dri-sump test for use in testing under dispenser containment, containment sumps, transition sumps and spill buckets on state of Alaska regulated UST facilities as long as the tester has the equipment manufacturer's training and certification along with either a state of Alaska UST Installer or Inspector certification. Our regulation (18 AAC 78) establishes the NWGLDE listing as the sole source for certification of allowable leak detection equipment used in Alaska. Since Dri-sump has been 3rd-party certified by Ken Wilcox and is included on the NWGLDE list, we will accept it for use in Alaska. The PowerPoint was very informative and helped greatly in clarifying how it all works.

I will put out an email to all of our state-certified UST workers informing them that this option is available and will share your info@dri-sump.com email address with them.

Sorry it took so long to review your submittal...we have been super swamped with higher priority tasks up until a few weeks ago.

Larry Brinkerhoff

UST Prevention Manager

Alaska Department of Environmental Conservation

555 Cordova St

Anchorage, AK 99501

907-269-3055 (Phone)

907-269-7687 (Fax)

UST Web Page:

<http://dec.alaska.gov/spar/csp/tanks.htm>