



Danny Brevard <danny@accent-us.com>

Dri-sump Containment Tightness testing

Mon, May 18, 2020 at 2:09 PM

Hi Justin,

Thank you for the email. I have attached our current report form. Can you provide us with your current hydro-static test report form, or where we can find it? We will need it to make sure we train any testers in OK properly to your stipulations.

Hope you, y'all and yours are all doing good during this COVID-19 time!!

Thanks for letting us serve,

David Brevard: Dri-Sump, TCEQ OSS A/B, LA A-B Op, API A-B Op, Petro-Tite, NACE CP1, CP2 52012

P. O. Box 3289

Lufkin, TX 75903-3289

409-842-0150

936-202-2171 FAX

www.dri-sump.com

david@dri-sump.com

Please consider the environment before printing this email.

On Mon, May 18, 2020 at 2:04 PM Justin Lankford <Justin.Lankford@occ.ok.gov> wrote:

David,

Hope all is well we have been discussing Dri-Sump and accepting it as a form of containment testing in Oklahoma. When we observed your demonstration you stated that you considered a containment that had water surrounding it and it was dry to be a passing hydrostatic test we will not be accepting this as a passing test. We are planning on accepting your method with the following stipulations

1. If a location is unable to test using DRI-SUMP due to high water around the containment the owner will be required to test using another approved method.
2. The use of an Oklahoma approve form will be required.

To comply with the use of Oklahoma required forms please email myself and Brock the forms you are currently using and we will modify so it has our headings and stipulations. After we have made our modifications we will email a copy back to you for your approval and once we have all agreed you will then be able to test in Oklahoma.

Justin Lankford

Manager of Compliance and Inspection

Oklahoma Corporation Commission

(405) 203-1699 Cell

(405)522-5265 office

Justin.lankford@occ.ok.gov

www.occeweb.com

[Quoted text hidden]



Dri-sump Report Form-rev10-19.docx
23K