



Danny Brevard <danny@accent-us.com>

request for acceptance of Dri-sump

Bondi, Frank D (DEC) <Frank.Bondi@dec.ny.gov>
To: "danny@accent-us.com" <danny@accent-us.com>
Cc: "Hale, Kevin (DEC)" <kevin.hale@dec.ny.gov>

Mon, Jul 1, 2019 at 1:31 PM

Good afternoon Danny,

Kevin is out of the office today so he asked for me to help follow up.

At this time, New York does not have periodic sump and spill bucket testing as part of our bulk storage regulations. Therefore, we are not in a position to make determinations on any related testing methods. These requirements are currently only on the federal level and because of this, EPA is the implementing agency; any testing method used must meet their requirements.

Let us know if you have any questions.

Thanks,

Frank Bondi

Assistant Engineer, Division of Environmental Remediation

New York State Department of Environmental Conservation

625 Broadway, Albany, [NY 12233](#)

P: (518) 402-9573 | frank.bondi@dec.ny.gov

www.dec.ny.gov |  |  | 

From: Danny Brevard <danny@accent-us.com>
Date: June 30, 2019 at 11:04:45 AM EDT
To: "Hale, Kevin (DEC)" <Kevin.Hale@dec.ny.gov>
Subject: Re: request for acceptance of Dri-sump

ATTENTION: This email came from an external source. Do not open attachments or click on links from unknown senders or unexpected emails.

[Quoted text hidden]



Danny Brevard <danny@accent-us.com>

request for acceptance of Dri-sump

Danny Brevard <danny@accent-us.com>

Mon, Jul 1, 2019 at 3:10 PM

To: "Bondi, Frank D (DEC)" <Frank.Bondi@dec.ny.gov>

Cc: "Hale, Kevin (DEC)" <kevin.hale@dec.ny.gov>, "info@Dri-sump.com" <info@dri-sump.com>

Thanks Frank!

Dri-sump has conducted the EPA 3rd party testing for the more stringent Non-volumetric tank tightness test so we easily exceed the 0.10gph and actual when compared to a hydrostatic test, we exceed 0.05gph leak rate. The tests were conducted by Ken Wilcox Associates twice. Dri-sump passed both sets with 100% accuracy (one in at the KWA lab facility and one in actual field tests with sumps in UST type backfill soils and also in a clay/silt compacted soil). These were evaluated by the National Work Group on Leak Detection Evaluations and are published as an accepted method. We have followed all EPA requirements and more so that we could satisfy everyone. Thanks again for your reply and all the research and review conducted by Kevin and everyone at your agency!

Sincerely,

Danny Brevard; PG

[Click for Brevard Curriculum Vitae](#)

[Click for Brevard LinkedIn Profile](#)

AC'CENT Corporate Offices

P. O. Box 3289

Lufkin, TX 75903-3289

936-225-5000 Voice and Contact Info

936-202-2171 or 936-853-2871 FAX

www.accent-us.com

danny@accent-us.com

ACCENT is a Professional Geoscience Firm #50150,

UST Licensed Contractor #CR0000072 and LPST Corrective Action Specialist #CS0000068

[Quoted text hidden]