



Danny Brevard <danny@accent-us.com>

West Virginia Acceptance of NWGLDE listing for Dri-sump™ Containment Tightness Test Method

Porter, Ruth M <Ruth.M.Porter@wv.gov>

Thu, Apr 4, 2019 at 6:44 AM

To: Danny Brevard <danny@dri-sump.com>, "Palmer, Jenna D" <Jenna.D.Palmer@wv.gov>, "Sizemore, Joe M" <Joe.M.Sizemore@wv.gov>

Cc: "info@Dri-sump.com" <info@dri-sump.com>, "Mauzy, Eric W" <Eric.W.Mauzy@wv.gov>, "Honaker, Cleve A" <Cleve.A.Honaker@wv.gov>, "McCune, Melissa D" <Melissa.D.McCune@wv.gov>

Mr. Brevard

WV does not approve methods or equipment. WV does recognizes and accepts methods listed on NWGLDE as long as they are performed in strict adherence with the conditions outlined in NWGLDE. Installations and testing in WV can only be performed by WVDEP certified personnel. Class A certification is required for installation of most equipment, especially any equipment that requires you to "break ground" (i.e. penetrate the ground surface). Class F certification is the applicable certification for spill bucket testing. WV certifies individuals not companies. The certified individuals must be physically on-site performing the work or on-site performing direct oversight of the work. If any contamination is discovered (visually, through odor, or other means) during work at a facility it must be reported to the WVDEP spill line.

You can find applications for the worker certification program on our website. After review and approval of an application, Jenna Palmer can schedule the appropriate tests.

I request that when you become certified in the State and are preparing to install and perform testing that you notify us a minimum of 72 hours ahead of time so we can have an inspector in attendance to view the installation of the points and observe the testing procedure.

Ruth

Ruth M. Porter

Tanks Program Manager

601 57th Street S.E.

Charleston, WV 25304

Phone 304-926-0499 x 1007

Fax 304-926-0452

From: Danny Brevard <danny@dri-sump.com>
Sent: Sunday, March 17, 2019 2:19 PM
To: Palmer, Jenna D <Jenna.D.Palmer@wv.gov>; Porter, Ruth M <Ruth.M.Porter@wv.gov>; Sizemore, Joe M <Joe.M.Sizemore@wv.gov>
Cc: info@dri-sump.com
Subject: Re: West Virginia Acceptance of NWGLDE listing for Dri-sump™ Containment Tightness Test Method

Hello Folks,

[Quoted text hidden]

[Quoted text hidden]