



Mississippi Acceptance of NWGLDE listing for Dri-sump™ Containment Tightness Test Method

Wesley McCain <wmccain@mdeq.ms.gov>

Mon, Apr 6, 2020 at 3:45 PM

To: Danny Brevard <danny@dri-sump.com>

Cc: Lynn Chambers <LChambers@mdeq.ms.gov>, Mike Pigford <mpigford@mdeq.ms.gov>, Brandon StClair <BSTCLAIR@mdeq.ms.gov>, "info@Dri-sump.com" <info@dri-sump.com>

Danny,

Thank you for clarifying and modifying form to indicate when hydrostatic testing is necessary.

We approve of the use of Dri-Sump for sump integrity testing following the procedures you provided.

The explanation I sent to you for clarification is copy written. I did not mention that previously. I would recommend not attaching the explanation to the form. All certified installers / technicians in MS should be well aware of the explanation

to where I don't think it's necessary to attach it to the Dri-Sump form. As long as they are aware of it (and they should be) that is sufficient notification.

Thank you again for your time and discussing it. It was also helpful on my end.

If you need anything let us know.

Thanks,

Wesley McCain, P.E.

ECED – UST Branch

Mississippi Department of Environmental Quality

8 County Road 413 Oxford, MS 38655

Office: 662-234-3784

[Quoted text hidden]