



Danny Brevard <danny@accent-us.com>

Re: South Dakota Acceptance of NWGLDE listing for Dri-sump™ Containment Tightness Test Method

Florentz, Terry <Terry.Florentz@state.sd.us>
To: "Danny@Dri-sump.com" <Danny@dri-sump.com>

Mon, May 6, 2019 at 4:43 PM

Mr. Brevard

South Dakota will accept testing methods that have been third-party tested and accepted by NWGLDE. Just curious what you estimate as a cost per sump tested with your method and what you estimate per sump for the "costly" hydrostatic method.

Terry Florentz, P.E.

Natural Resources Engineering Manager

SD Dept. of Environment & Natural Resources

605-773-3296