



Danny Brevard <danny@accent-us.com>

Acceptance for Dri-sump Containment Tightness Testing method in New Hampshire

Juranty, Mike <Michael.Juranty@des.nh.gov>

Thu, Feb 7, 2019 at 11:47 AM

To: Danny Brevard <danny@accent-us.com>

Cc: "info@Dri-sump.com" <info@dri-sump.com>, "Corliss, Charles" <Charles.Corliss@des.nh.gov>, "Jones, Matthew" <Matthew.Jones@des.nh.gov>

Hi Danny,

Because the test method is listed http://nwglde.org/evals/accent_environmental_a.html, by rule it is acceptable for use in NH. Please reply with any other questions.

Thank you,

Mike Juranty

NH Department of Environmental Services

(603) 271-8873

From: Danny Brevard <danny@accent-us.com>

Sent: Thursday, February 7, 2019 10:44 AM

To: Juranty, Mike <Michael.Juranty@des.nh.gov>

Cc: info@Dri-sump.com

Subject: Acceptance for Dri-sump Containment Tightness Testing method in New Hampshire

[Quoted text hidden]