



Danny Brevard <danny@accent-us.com>

Alabama NWGLDE Acceptance of NWGLDE listing for Dri-sump™ Containmment Tightness Test Method

Batchelor, David <david.batchelor@adem.alabama.gov>
To: Danny Brevard <danny@accent-us.com>

Fri, Feb 1, 2019 at 8:29 AM

Danny,

I am familiar with the method and listing as I am one of the new members of NWGLDE. Now that the method has been listed, it may be used in Alabama, however our current sump testing form is more geared towards the more traditional hydrostatic, pressure or vacuum testing. The form is linked below:

<http://adem.alabama.gov/DeptForms/Form557.pdf>

When completing the form, select manufacturer's instructions for test method and fill out what you can on the form (for example, you will not have a water drop using this method). If Dri-sump has a standard datasheet that is meant to be used with the test, that should be submitted with our form just for clarity. If it does not, I would probably recommend writing something along the lines of "line visible" or "no line visible" in the water drop field (since that is looking for a tangible test result), and make sure to state that the Dri-sump method was used in the "code of practice or manufacturer's instructions used" line near the top. For extra clarity, you could also use the repair comments box at the bottom to say "presence of laser dot indicates the sump is tight" or "presence of visible laser beam indicates sump is not tight" but I would not call that necessary. In the future, we may have a new form that would be more accommodating to alternative methods, but this will have to do for now.

And since you mentioned our contractor certification, anyone doing this test does NOT need that certification since this is just a sump test, not a UST installation, closure or repair.

David Batchelor

Environmental Engineering Specialist, Senior

Groundwater Branch, Land Division

Alabama Department of Environmental Management

Post Office Box 301463

Montgomery, Alabama 36130-1463

Phone and Fax Number: (334) 271-7937

E-mail: david.batchelor@adem.alabama.gov



adem.alabama.gov

Did you know that on December 8, 2017 Alabama's revised UST regulations became effective? A detailed summary of the significant changes and important implementation dates can be found [here](#).

For additional information on the UST program, please go to

<https://app.adem.alabama.gov/custard>

From: Danny Brevard <danny@accent-us.com>

Sent: Friday, February 1, 2019 7:41 AM

To: Batchelor, David <david.batchelor@adem.alabama.gov>

Cc: info@Dri-sump.com

Subject: Alabama NWGLDE Acceptance of NWGLDE listing for Dri-sump™ Containmment Tightness Test Method

Dear David,

[Quoted text hidden]

[Quoted text hidden]