



Danny Brevard <danny@accent-us.com>

---

## Dri-sump(R) Containment Tightness Test Method

---

**Kwan, Roxanne S** <roxanne.kwan@doh.hawaii.gov>  
To: Danny Brevard <danny@accent-us.com>  
Cc: "Okino, Nicole" <nicole.okino@doh.hawaii.gov>

Tue, Dec 17, 2019 at 5:15 PM

Hello, Danny

I am following up on the email sent to Nicole Okino. Thank you for the information about your sump testing methods. Hawaii does not have a certification program.

The Dri-Sump test method has meet the NWGLDE standards. This meets our requirement in the Hawaii Administrative Rules 11-280.1-35(a)(1)(B)(ii) of a code of practice developed by a nationally recognized association or independent testing laboratory to test containment sumps used for interstitial monitoring at least once every three years.

Roxanne

[Quoted text hidden]